

	Recovery Boiler	Recovery Boiler	Power Boiler	Power Boiler
	Particulate		Particulate	
Limit - Approval	77 mg/Rm3	% of Limit	150 mg/Rm3	% of Limit
2015 - July	4.0	5%	148	99%
2015 - September	4.0	5%	190	127%
2015 - November	2.3	3%	111	74%
2016 - March	4.4	6%	123	82%
2016 - June	2.3	3%	114	76%
2016 - August	12.3	16%	136	91%
2016 - December	3.0	4%	157	105%
2017 - March	0.8	1%	113	75%
2017 - June	0.2	0%	224	149%
2017 - September	1	2%	72	48%
2017 - December	5	6%	50	33%